



**San Joaquin Valley**  
AIR POLLUTION CONTROL DISTRICT



APR 28 2015

Brent Winn  
Aera Energy LLC  
PO Box 11164  
Bakersfield, CA 93389

**Re: Notice of Final Action - Minor Title V Permit Modification**  
**District Facility # S-1547**  
**Project # 1142662**

Dear Mr. Winn:

The Air Pollution Control Officer has modified the Title V permit for Aera Energy LLC by incorporating Authority to Construct (ATC) S-1547-1334-0. The ATC authorizes replacement of a steam generator for compliance with Rule 4320.

Enclosed is the modified Title V permit. The application and proposal were sent to US EPA Region IX on November 10, 2014. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,

Arnaud Marjollet  
Director of Permit Services

AM:rue

Enclosures

cc: Gerardo C. Rios, EPA (w/enclosure) via email

**Sayed Sadredin**  
Executive Director/Air Pollution Control Officer

---

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061  
[www.valleyair.org](http://www.valleyair.org)

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585  
[www.healthyairliving.com](http://www.healthyairliving.com)

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1547-1334-1

**EXPIRATION DATE:** 05/31/2016

**SECTION:** NE 33    **TOWNSHIP:** 28S    **RANGE:** 21E

**EQUIPMENT DESCRIPTION:**

62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (#107, GEN SITE 3363) WITH NORTH AMERICAN ULTRA-LOX NOX MAGNA-FLAME GLE BURNER AND FLUE GAS RECIRCULATION

## PERMIT UNIT REQUIREMENTS

---

1. Copies of all fuel invoices showing quantity and delivery points of supplier-certified gas delivered and copies of quality terms of supplier-certified gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or EPA Method 6B; or EPA Method 8; or ARB Methods 8 or 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H2S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. Duration of startup and shutdown shall not exceed 2 hours each per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Natural gas fuel sulfur content shall not exceed 1.0 gr S/100 scf. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
8. Emission rates, except during startup, shutdown, initial commissioning and refractory curing, shall not exceed any of the following PM10: 0.007 lb/MMBtu, VOC: 0.007 lb/MMBtu, NOx (as NO2): 0.0061 lb/MMBtu or 5 ppmv @ 3% O2, or CO: 50 ppmv @ 3% O2. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. Emission rates during refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO<sub>2</sub>; sulfur - 200 pounds of SO<sub>2</sub> per hour, or 2000 ppmv as SO<sub>2</sub>, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO<sub>2</sub> - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rule 4301, 4405, 4406, and 4801] Federally Enforceable Through Title V Permit
10. The permittee shall monitor and record the stack concentration of NO<sub>x</sub>, CO, and O<sub>2</sub> at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
11. If either the NO<sub>x</sub> or CO concentrations corrected to 3% O<sub>2</sub>, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
12. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. The permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO, and O<sub>2</sub> measurements, (2) the O<sub>2</sub> concentration in percent and the measured NO<sub>x</sub> and CO concentrations corrected to 3% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Source testing to measure natural gas-combustion NO<sub>x</sub> and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

17. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, NO<sub>x</sub> (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO<sub>x</sub> (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H<sub>2</sub>S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
19. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rule 4320] Federally Enforceable Through Title V Permit
20. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.